

Evidence of Performance

Partial test: „Forcing off“, „Twist-off“ regarding EN 13126-3 : 2011 section 7.13



Test Report

No. 22-002513-PR01

(PB+KB-G05-03-en-01)

Client	KAYA-PEN PLASTIK SAN. VE TIC. LTD. STI. OSB 8 CAD. No: 5 57000 MERKEZ / SINOP Turkey	
Product	Lockable window handle	
Designation	Lockable window handle with click and Push-lock mechanism	
Performance-relevant product details	Material:	Aluminum
	Mounting distances:	43 mm
	Method of attaching:	screws
	The number of fasteners:	2 pc
	Fasteners:	M5 x 45 mm
	Handle width:	28 mm
	Handle length:	145 mm
	Handle housing (WxLxH):	28 mm x 65 mm x 11.5 mm
Special features	-/-	

Basis

EN 13126-1 : 2011
EN 13126-3 : 2011

Test standards:
EN 13126-3 : 2011

Equivalent national versions (e. g. DIN EN)

Representation



Validity

The data and detailed results given refer solely to the tested / described test specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be applied under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Result

Evaluation

The window handle complies with the requirements of EN 13126-3 : 2011, table 4 class 2 regarding protection against "100 Nm twist-off", "forcing off" out of test section 7.13

ift Rosenheim

07.06.2022

Konrad Querengässer, Dipl.-Ing. (FH)
Head of Testing Department
Security/Safety Testing

Erwin Heimbuchner
Operating Testing Officer
Security/Safety Testing

Notes on publication

The ift-Guidance "Advertising with ift test documents" applies.

The cover sheet can be used as an abstract.

The report contains a total of 8 pages.