

Evidence of Performance

Hardware for windows and door-height windows EN 13126-3 : 2011



Test Report

No. 20-001645-PR01

(PB+KB-G05-03-en-01)

Client KAYA-PEN PLASTIK SAN. VE TIC. LTD. STI.
OSB 8 CAD. No: 5
57000 MERKEZ / SINOP
Turkey

Product Rotating handle with click mechanism

Designation Aluminum Window Handle
Art. No.: KP5011.101.ST

Performance-relevant product details Material: Aluminum alloy
Mounting distances: 43 mm
Method of attaching: screws
The number of fasteners: 2 pc
Fasteners: M5 screws
Handle length: approx. 125 mm
Handle housing (WxLxH): 65 mm x 28 mm x 12 mm

Special features -/-

Basis

EN 13126-1 : 2011
EN 13126-3 : 2011

Test standards:
EN 13126-3 : 2011

Equivalent national versions (e.g. DIN EN)

Representation



Instructions for use

This test report demonstrates compliance with the requirements for tilt & turn, tilt-first and turn-only hardware as per EN 13126-8 : 2017

This test report does not replace the EC Certificate of Conformity. Observe the provisions of EN 13126-8 : 2017 for marking and evaluation of conformity of construction products.

Validity

The data and detailed results given refer solely to the tested / described test specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be applied under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 12 pages.

Result

Classification according to EN 13126-3 : 2011

Category of use	Durability of use	Mass resistance	Fire safety	Safety in	Corrosion resistance	Security	Applicable part	Test sizes
2	4/180	-	0	1	5	0/0	3/C1	-

ift Rosenheim

22.11.2021

Konrad Querengässer, Dipl.-Ing. (FH)
Head of Testing Department
Security/Safety Testing

Erwin Heimbuchner
Operating Testing Officer
Security/Safety Testing